

Georgetown Divide Public Utility District



Domestic Water

Irrigation Service

On-Site Waste Disposal

1946~ 2012 Reflecting on the Past. Planning for the Future.

The Georgetown Divide Public Utility District is pleased to present this information to our customers, which includes two documents mandated by the California Department of Public Health **(1) Annual Water Quality Report / Consumer Confidence Report** and **(2) a State Notification Letter** regarding the District's water treatment processes).

DEAR WATER USER,

This report provides a snapshot of your water quality. We are pleased to report that in 2011, as in years past, your water met all US Environmental Protection Agency (EPA) and state drinking water health standards. The District vigilantly safeguards its water supplies and once again, our water system has not violated a maximum contaminant level or any other water quality standard. Included in these pages are details on where your water comes from, what it contains and how it compares to state standards. For additional information on water quality, customers may contact GDPUD at (530) 333-4356.

About Contaminants

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. GDPUD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Some People Are More Vulnerable

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA and Centers for Disease Control (CDC) guidelines on appropriate means to lessen risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791) or find it on EPA's website www.water.epa.gov/drink/index.cfm.

Natural Materials Can Enter Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, reservoirs and canals. As water travels over the surface of the land it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, that may come from septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, septic systems and agricultural application.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

(Continued on back page)

Georgetown Divide Public Utility District

GDPUD Consumer Confidence Report

2011 Calendar Year (Reported in 2012)

Primary Drinking Water Standards--Health Related

Parameters/	Constituents	Unit	MCL	PHG or (MCLG)	Your Water		Meets Standards	Typical Source of Contaminant
					Lake Walton WTP Service Area	Auburn Lake Trails WTP Service Area		
Microbiological Primary Drinking Water Standards								
Turbidity	NTU	TT=1 NTU	0.1	0.1	0.38 highest (0.05 average)	0.22 highest (0.04 average)	YES	Soil runoff
					TT=95% of samples ≤ 0.3 NTU	n/a		
TURBIDITY NOTE: Turbidity is a measurement of the cloudiness of the water or the level of suspended matter in the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. High turbidity can hinder the effectiveness of disinfectants. In reporting turbidity, the highest single measurement and the lowest monthly percentage of samples meeting the turbidity limits are specified.								
Total Coliform Bacteria (Total Coliform Rule) (weekly)		no more than one positive monthly sample	0	0	0	0	YES	Naturally present in the environment.
Fecal Coliform and E. Coli (Total Coliform Rule) (weekly)		A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or E. Coli positive	0	0	0	0	YES	Human and animal fecal waste
COLIFORM NOTE: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.								

Inorganic Chemicals- Source Water Results

Aluminum	ppb	1000	600	63	ND	YES		
Disinfection By-products, Disinfectant Residuals, and Disinfection Byproduct Precursors								
THMs (Total Trihalomethanes)	ppb	80	NA	27.4 running annual average 14.5 LRAA (13.0-17.0 range)	27.4 running annual average 40.25 LRAA (29.0-49.0 range)	YES	By product of drinking water disinfection	
Haloacetic Acids	ppb	60	NA	20.1 running annual average 10.75 LRAA (8.4-16.9 range)	20.1 running annual average 29.5 LRAA (16.5-47.7 range)	YES	By product of drinking water disinfection	
Chlorine	ppm	MRDL = 4.0	MRDLG=4	0.81 average (0.78 to 0.85 range)	0.88 average (0.68 to 1.0 range)	YES	Drinking water disinfectant added for treatment	

Secondary Drinking Water Standards - Aesthetic

Parameters / Constituents	Unit	Secondary MCL	PHG or (MCLG)	Your Water		Meets Standards	Typical Source of Contaminant	
				Walton Lake WTP Service Area	Auburn Lake Trails WTP Service Area			
Source water results								
Note: There are no PHG's or MCLG's for constituents with secondary drinking water standards because these are not health-based, but set on the basis of aesthetics.								
Aluminum	ppb	200		63	ND	YES	Erosion of natural deposits; residual from some surface water treatment processes	
Aggressive Index		NS		9.15 (slightly corrosive)	9.62 (slightly corrosive)	YES	Natural or industrially-influenced balance of hydrogen, carbon and oxygen in the water; affected by temperature and other factors.	
Iron	ppb	300		110	150	YES	Leaching from natural deposits; industrial wastes	
Manganese	ppb	50		10	ND	YES	Leaching from natural deposits	
Odor-Threshold	units	3		ND	1	YES	Naturally occurring organic materials	
Total Dissolved Solids (TDS)	ppm	1000		20	21	YES	Runoff/leaching from natural deposits	
Specific Conductance (EC)	micromhos	1600		22	25	YES	Substances that form ions when in water; seawater influence	
Chloride	ppm	500		0.68	0.73	YES	Run-off/leaching from natural deposits; seawater influence	
Sulfate	ppm	500		0.54	0.58	YES	Run-off/leaching from natural deposits' industrial wastes.	
Additional Constituents-Source Water Results								
Alkalinity as Calcium Carbonate	ppm	NS	NS	11	12	YES	Naturally occurring in water	
Calcium	ppm	NS	NS	2.1	2.5	YES	Naturally occurring in water	
Potassium	ppm	NS	NS	1.0	ND	YES	Naturally occurring in water	
pH (daily treated water)	units	6.5-8.5	NS	8.07 average (7.48 - 8.20 range)	8.19 average (8.08 - 8.30 range)	YES	Naturally occurring in water	
Sodium	ppm	NS	NS	1.6	1.5	YES	Sodium refers to the salt present in the water and is generally naturally occurring.	
Total Hardness	ppm	NS	NS	8.2	9.4	YES	Naturally occurring in water, generally from magnesium and calcium.	

Definitions

MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. Primary MCL's are set as close to the PHG's (or MCLG's) as is economically and technologically feasible. Secondary MCL's are set to protect the odor, taste, and appearance of drinking water.	PHG: Public Health Goal; The level of a contaminant in drinking water below which there is no known or expected risk to health. PHG's are set by the California Environmental Protection Agency.
MCLG: Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's are set by the U.S. Environmental Protection Agency.	RAI: Regulatory Action Level is the concentration of a contaminant which if exceeded, triggers treatment or other requirements that a system must follow.
MRDL: Maximum Residual Detection Limit. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.	ND: Non-Detected
MRDLG: Maximum Residual Detection Limit Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.	NS: No Standard
NTU: Nephelometric Turbidity Units. A measurement of water clarity.	NA: Not Applicable
Primary Drinking Water Standard: MCL's for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.	ppm: parts per million
	ppb: parts per billion
	mg/L: milligrams per liter (1 mg/L = 1 ppm)
	pCi/L: pico curies per liter
	TOC: Total Organic Carbon
	TT: Treatment Technique is a required process intended to reduce the level of a contaminant in drinking water.
	LRAA: Locational Running Annual Average

Note to GDPUD Customers: Some samples, though representative, are more than a year old. The state allows us to monitor some constituents less than once per year because the concentration of these constituents does not change frequently.

How Data is Collected and Reported—The tables presented on these pages list all of the drinking water contaminants that were detected during the 2011 calendar year. The presence of these contaminants does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in these tables was collected during 2011. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. During 2011, the district conducted monitoring for an additional 102 contaminants, none of which were detected in our water supplies. In addition, the state waived testing for more than 30 additional contaminants that are sometimes tested. Some of the data in this Consumer Confidence Report, though representative of water quality, is more than one year old.

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

Georgetown Divide Public Utility District

PUBLIC NOTICE TO DISTRICT CUSTOMERS

OLDER WATER TREATMENT PROCESS DOES NOT MEET NEW STATE STANDARDS

Dear Customer,

The Georgetown Divide Public Utility District takes great pride in the high quality of the water we supply to our customers. In our many years of service, our water has always met or exceeded state and federal public health standards.

Even though our water continues to meet all of these standards, one of the methods in our water treatment process has become outdated under today's state standards. This is not surprising in a smaller, rural community where water treatment plants are older (the Auburn Lake Trails plant was built in 1971). It is financially challenging for a district with a small customer base to pay for millions of dollars in water system improvements.

Eight years ago, on February 9, 2004, the California Department of Public Health, Office of Drinking Water issued an administrative order (No. 01-09-04CO-002) that instructs the district to comply with state regulations regarding the filtration of drinking water. Printed here is the state's public notification message:

NOTIFICATION OF FAILURE TO COMPLY WITH DRINKING WATER TREATMENT STANDARDS

"The Georgetown Divide Public Utility District is providing this notice at the direction of the State of California Department of Public Health, Division of Drinking Water and Environmental Management (Department) to bring to your attention certain matters regarding the treatment of your drinking water supply.

The Department establishes standards for the quality of drinking water, including regulations for the quality of water supplies drawn from lakes and streams (i.e., surface water). If such water is inadequately treated, microbiological contaminants in the water may cause disease. Disease-causing organisms, if present, can cause symptoms including diarrhea, cramps, nausea, and possibly jaundice, and any associated headaches and fatigue. (These symptoms, however, are not just associated with disease-causing organisms in drinking water, but also may be caused by a number of factors other than your drinking water.)

District Summary

The Auburn Lake Trails (ALT) water treatment plant was considered to be state of the art when it was built, but the "in-line filtration" technology does not meet current standards. Your Board of Directors wants to provide the best possible service to customers but is also very concerned about costs and resulting impacts on water rates.

The district is making significant progress in bringing its water treatment facilities into compliance with current regulations. The new Auburn Lake Trails Water Treatment Plant, which will meet state and federal surface water treatment standards when complete, is on track to be completed by December 2013.

In the meantime, you may consider your water safe to drink.

Since it is infeasible to analyze treated water for all disease-causing organisms that may be present, the Department has established enforceable requirements (Surface Water Treatment Regulations) for treating surface water to reduce the risk of these adverse health effects. The regulations include specific criteria for filtering and disinfecting surface water to remove or destroy microbiological contaminants. Drinking water that is treated to meet these criteria is considered to be safe.

The Georgetown Divide Public Utility District water treatment plants use a filtration technology that is not among those listed in the Surface Water Treatment Regulations. Because the District has not demonstrated to the Department that its treatment plants provide a degree of treatment equivalent to the listed technologies, the plants are not considered to be in compliance with the Department's regulations. The District is currently working toward bringing its water treatment plants into compliance with the regulations or constructing new facilities that will comply with the regulations.

It is estimated that all improvements to the system will be made in 2013. The District will keep you informed on a regular basis of progress made to resolve this issue. If you have any questions regarding this notification, or our service, please call GDPUD at (530) 333-4356."

**GEORGETOWN DIVIDE
PUBLIC UTILITY DISTRICT**

PO BOX 4240, GEORGETOWN, CA 95634-4240
OFFICE HOURS: M—F 7:45 AM—4:30 PM



Your GDPUD Board Members

The Board meets regularly on the second Tuesday of each month, at 9:00 am at the District offices, located at 6425 Main Street in Georgetown.

Your board members are:

- Ray Griffiths, President
- Bonnie McLane, Vice President
- Kathy Otermat, Treasurer
- Norm Krizl, Director
- Bonnie Neeley, Director

(Continued from page 1)

**WATERSHED HEALTH
Water Source Assessment**

Source water protection is the primary barrier for providing safe drinking water. A contaminant that does not enter the water source does not need to be removed. An assessment of the district's drinking water source was completed in December 2002. The source is considered most vulnerable to the following activities for which no associated contaminants have been detected in the water supply: historic gas stations, historic mining operations, wastewater treatment systems, forest management activities, recreational use, storm drain and storm water discharges and illegal dumping. You may request a copy of the complete assessment or a summary at the GDPUD office or by contacting the CDPH District Engineer, at (916) 449-5600.

Water Quality Rules Explained

In order to ensure that tap water is safe to drink, the EPA and CA Department of Public Health (CDPH) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health. California notification levels are available on the Department's website www.cdph.ca.gov/certlic/drinkingwater/Pages/NotificationLevels.aspx

Your Water Supply

Your water originates in the Sierra, flows into Stumpy Meadows Reservoir and is transported through a Gold Rush-era canal system and pipes to the Walton Lake and Auburn Lake Trails water treatment plants. The Walton Lake plant serves the communities of Georgetown, Garden Valley, Kelsey and Greenwood. The Auburn Lake Trails plant serves Auburn Lake Trails, Cool and Pilot Hill. Both plants use a multi-barrier process to ensure the quality of your drinking water. Each plant uses liquid bleach to disinfect raw water before it undergoes treatment. The treatment process involves coagulation for the removal of fine particles, filtration using sand and anthracite, disinfection, and reduction of corrosivity through use of sodium carbonate. Treated water is stored in tanks and piped to customers.

Please note that GDPUD staff must conduct vegetation removal on private and public lands throughout the year to maintain District facilities.